

FORM A

(Form of application under sub section (1)/ Sub section (2) of section of the Madras Public Buildings (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 3 of the Madras Public Buildings (Licensing) Rules 1966.

From

THE CORRESPONDENT,
"SPECTRUM LIFE SCHOOL (CBSE)",
 DOOR No: 6/913,
 NETHAJI NAGAR 4TH CROSS,
 TRICHY ROAD,
 VAGURAMPATTY VILLAGE,
 NAMAKKAL TALUK & DISTRICT.
 PIN CODE: 637 001.

To

THE THASILDAR,
 NAMAKKAL

Sir

1. Intend / to use the building / to continue to use the existing public buildings / to use the existing building not at present used as a public building / which is situated in the site or plot of land, Town or Revenue Survey No's: 5/2A (Part), 5/2B (Part), 21/2, 13, 16, 17, Door No: 6/913 at Nethaji Nagar 4th Cross, Trichy Road, Vagurampatty Village, Namakkal Taluk & District, Pin code: 637 001 and specified in the statement enclosed as a public building for a period of **3 Years from 01.06.2025 To 31.05.2028.**
2. The year of construction and the present approximate cost of construction and purpose for which it is to be used or is being used as public building are also furnished in the statement accompanying this application.
3. I enclose a Challan for Rs. 2000/-
4. I also enclosed a certificate of structural soundness in the prescribed form by the Engineer **A. Venkatachalam, M.E., M.I.E., F.I.V., District Panel Engineer, Class-1A, Namakkal.**

Date:

Signature of the Owner of the Building

Enclosures : 1. Statement 20241203021464 dt. 04/12/2024.
 2. Challan for Rs. 2000/- towards the application fee.

Explanation : Separate application shall be made in respect of each building.

M. Anirudh

SENIOR PRINCIPAL
 SPECTRUM LIFE SCHOOL
 6/913, Nethaji Nagar, 4th Cross,
 Trichy Road, Namakkal - 637 001.



[Signature]
 PRINCIPAL
 SPECTRUM LIFE SCHOOL
 6/913, Nethaji Nagar 4th Cross,
 Trichy Road,
 Namakkal - 637 001.

STATEMENT ACCOMPANYING FORM-A

1. Door number of the building : Door No: 6/913
2. Location (Street No; Ward No : **“SPECTRUM LIFE SCHOOL (CBSE)”**,
Name of place, i, e., S.F.No's: 5/2A (Part), 5/2B (Part), 21/2, 13, 16, 17,
Corporation/Municipality/ Nethaji Nagar 4th Cross,
Trichy Road,
Vagurampatty Village,
Namakkal Taluk & District,
Pin code: 637 001.
3. Plinth Area/Year of Construction :

S. No.	Name of the Building with Description	Year of Construction With age	Future Life of Building	Plinth area of Building Sq.Ft	Approximate Cost of Construction Rs.	Floor area of the Building in Sq.Ft
<u>RCC ROOF SCHOOL BUILDING – K.G. BLOCK</u>						
1.	Ground Floor (including corridor & staircase)	2017 (7 Years)	53 Years	8,208.05	77,98,000.00	----
<u>RCC ROOF SCHOOL BUILDING – SENIOR BLOCK</u>						
1.	Ground Floor (including corridor, passage & staircase)	2017 (7 Years)	53 Years	37,498.35	3,56,23,000.00	----
2.	First Floor (including corridor, passage & staircase)	2017 (7 Years)	53 Years	26,470.66	2,38,24,000.00	----
3.	Second Floor (including corridor, passage & staircase)	2017 (7 Years)	53 Years	9,313.55	88,48,000.00	----

4. Purpose for which the Building is being used or proposed to be used : Class Rooms, Labs, Office Room, Principal Room & Toilet for CBSE School Purpose
5. Purpose for which the Building has hither to been used : - do -
6. Details of construction of the Building (Particulars of the foundation Soil, Specification of the various parts under) : Framed Structure R.C. Column, R.R. Masonry Footing, Brick Masonry in Cement Mortar, RCC Roof, Cement Flooring.

M. Anirudha
SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.



[Signature]
PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.


- a) Foundation : R.C. Column, R.R. Masonry in C.M
- b) Basement : - do -
- c) Super Structure : Brick Masonry and Plastered with
Cement Mortar
- d) Floor and Roof : Cement Flooring & RCC Roof
7. Period for which license is required : 3 Years
from **01.06.2025 To 31.05.2028**
8. Number of persons to be accommodated : Students – 1,350 No's
+
Staff – 130 No's

Date: 28.11.2024


Signature of the Owner of the building

M. Anipriya

SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.


Signature of the Engineer

Ln. E.A.VENKATACHALAM, M.E., M.Sc. (SIT) M.E., F.V.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, (S)
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024



PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.


FORM - B

Form of certificate of structural soundness under sub-section (4) of section 4 of the Madras public Buildings (licensing) Act 1965 (Madras act 13 of 1965) referred to in rule 4 of the Madras public buildings (licensing) Rules 1965.

I certify that I have Inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a public building for the purpose noted in the statement. The Structural Soundness of the building has been verified in to account the loading as per the latest Indian standard. A license to the period of 3 Years :

from **01.06.2025 To 31.05.2028.**

Date: 28.11.2024


Signature of the Engineer

L.D.E.R.A.VENKATACHALAM, M.E., M.Sc.(RV)M.E., P.V.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-08
DISTRICT PANEL ENGINEER CLASS -1A, Ⓢ
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024


STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building (door no, street & name of place)	Age of the Building	Purpose for the building is certified for use	Period for which the building will be Structurally Sound	No. of persons to be accommodated	Remarks
"SPECTRUM LIFE SCHOOL (CBSE)", Door No: 6/913, Nethaji Nagar 4 th Cross, Trichy Road, Vagurampatty Village, Namakkal Taluk & District. Pin code: 637 001.	2017 (7 Years)	Class Rooms, Labs, Office Room, Principal Room & Toilet for CBSE School Purpose	3 Years from 01.06.2025 To 31.05.2028	Students- 1,350 No's + Staff - 130 No's	----


This certificate will not hold good in case of natural calamities such as fire, flood and earthquake.


This certificate is not valid if the Applicant makes any Additions (or) modifications without prior Approval.

Date: 28.11.2024


Signature of the Engineer

L.D.E.R.A.VENKATACHALAM, M.E., M.Sc.(RV)M.E., P.V.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-08
DISTRICT PANEL ENGINEER CLASS -1A, Ⓢ
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024


H. Anirmiya
SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913 Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.


PRINCIPAL
SPECTRUM LIFE SCHOOL,
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.

DECLARATION

I **A.VENKATACHALAM** Son of **M.MATHIYAPPA GOUNDER** Residing at No:29/57, Salem Road, Near K.S. Theatre, Namakkal do hereby declare that I possess the qualification and experience specified in the table to Rule 2 of the public Building (licensing) Rules 1966 for issuing the certificate of structural soundness of the building covered by this certificate.

- i) Name and address (in block letters) : **A. VENKATACHALAM**
ARRUL ASSOCIATES,
No.29/57, Salem Road,
Near K.S.Theatre, Namakkal.
- ii) Engineering qualification : **M.E., (Structural) M.I.E., F.I.V.,**
Chartered Engineer
Government Approved Engineer,
Registered Valuer.
- iii) Numbers of years of experience and nature thereof : **25 Years of practical experience in**
all types of construction and valuation works


DISTRICT PANEL ENGINEER CLASS- IA

Proceeding of the District Collector, Namakkal & Chennai Chief Engineer (General) Public Works Department, Lt No.AEE/T1/AE I/60992/2010. Dt.27.07.2010

Date: 28.11.2024

M. Anipriya

SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.


Signature of the Engineer

Lt. E.A.VENKATACHALAM, M.E., M.Sc. (RM) M.E., F.V.,
CHARTERED ENGINEER, REGISTERED VALUER-C4/C5-C6
☉ DISTRICT PANEL ENGINEER CLASS -1A, ☉
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Call : 98427 57507, 98427 33024


PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.

CERTIFICATE OF STABILITY

FORM – C

Form of certificate of structural soundness under sub section – 4 of the Tamilnadu Public Building (licensing) Act (Tamil Nadu Act 13 of 1965 referred to in rule of the Tamilnadu public Building (Licensing) rule 1965.

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation :

- | | | |
|--|---|--|
| i. Depth below ground level | : | 1.83 M |
| ii. Nature of soil met with at foundation level | : | Hard Gravelly Soil below ordinary soil |
| iii. Pressure at foundation | : | RCC Roof Building - 18.00 tones/sqm |
| iv. Probable safe bearing capacity of the
of the soil met with at foundation) | : | 25 tones /sqm |

2) Superstructure:

- | | | |
|--|---|---|
| i. Maximum stress in the most critical section of masonry and concrete | : | Brick Masonry in Cement Mortar
RCC Roof Building – 22.45 tons/sqm |
| ii. Nature of masonry and concrete and its safe permissible stress | : | Brick Masonry and plastered with
Cement Mortar = 40 tones/sqm,
Framed Structure RCC = 15 N/ Sqm |


The Structural Soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian standards code of practice and declare that the building for the purpose noted in the statement, A license may be granted for the period of 3 Years .


from **01.06.2025 To 31.05.2028.**

Date: 28.11.2024

Signature of the Engineer


L. E. A. VENKATACHALAM, ME, M.Sc., (P) ME, RV,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, 
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salam Road, Namakkal-637 001.
Call : 98427 57507, 98427 33024


SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.


PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.


STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building Door no, street, and Name of place	Age of the Building	Number of Stories	Short description of Structures Steel/RCC Framed/ Load bearing Masonry	Purpose for which the Building is certified to Use	The Period for which the building will be Structurally sound	Number of persons to be accommodated
(1)	(2)	(3)	(4)	(5)	(6)	(7)
"SPECTRUM LIFE SCHOOL (CBSE)" , Door No: 6/913, Nethaji Nagar 4 th Cross, Trichy Road, Vagurampatty Village, Namakkal Taluk & District. Pin code: 637001.	2017 (7 Years)	Ground, First & Second Floor Only	RCC Framed Structure	Class Rooms, Labs, Office Room, Principal Room & Toilet for CBSE School Purpose	3 Years from 01.06.2025 To 31.05.2028	Students- 1,350 No's + Staff - 130 No's


This certificate will not hold good in case of natural calamities such as fire, flood and Earthquake.


This certificate is not valid if the Applicant makes any Additions (or) modifications without prior Approval.

Date: 28.11.2024


 Signature of the Engineer

Ln. E. A. VENKATACHALAM, M.E., M.Sc., (P)/M.E., P.V.,
 CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
 DISTRICT PANEL ENGINEER CLASS -1A,
 APPROVED VALUER FOR BANKS,
 ARRUL ASSOCIATES,
 29/57, Salem Road, Namakkal-637 001.
 Cell : 98427 87507, 98427 33024


 SENIOR PRINCIPAL
 SPECTRUM LIFE SCHOOL
 6/913, Nethaji Nagar, 4th Cross,
 Trichy Road, Namakkal -637 001.


 PRINCIPAL
 SPECTRUM LIFE SCHOOL
 6/913, Nethaji Nagar 4th Cross,
 Trichy Road,
 Namakkal - 637 001.

FORM - 'E'

Form of Report to be made to the Competent Authority by Inspecting Authorities or Officers appointed Under Section 238 of the Madras Public Building (Licensing Act 1965 Madras Act 13 of referred to in rule 7 of the Madras Public Building (Licensing) Rule 1966.

- | | |
|---|---|
| 1. Name and designation of Inspecting authority or Officer appointed of having Jurisdiction Under Other act of Law. | Er. A. VENKATACHALAM,
District Panel Engineer- Class 1A |
| 2. Location of the Building Inspected (Door No. Street., Name of Place i.e. Municipal Corporation/ Municipality Union/Township/Cantonment | "SPECTRUM LIFE SCHOOL (CBSE)",
S.F.No's: 5/2A (Part), 5/2B (Part), 21/2, 13, 16, 17,
Door No: 6/913,
Nethaji Nagar 4 th Cross,
Trichy Road,
Vagurampatty Village,
Namakkal Taluk & District.
Pin code: 637 001. |
| 3. Date of Inspection | 27.11.2024 |
| 4. Purpose for which the Building is Used | CBSE School Purpose |
| 5. Nature of defects Noticed | No defects |
| 6. Suggestions for rectifying defects | No |
| 7. If in a dangerous Condition immediate Steps recommended to be taken | No |

PLACE : NAMAKKAL

DATE : 28.11.2024

M. Anirriya

SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.

A. Venkatachalam

Signature of the Engineer

Lt. Er. A. VENKATACHALAM, ME, M.Sc. (RM) ME, PV,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A,
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
26/57, Salem Road, Namakkal-637 001.
Call : 98427 57507, 98427 33024

J. J. J.

PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.

Proceedings of the District Collector, Namakkal
Present: Tmt.S.Madumathi, I.A.S.

Roc No 30642/2010/C2

Dated: 03.01.2011

Sub:Tamilnadu Public Buildings-(Licensing) Rules 1965-
Drawing of Panel of Registered Engineers under Rule 11-
Application of Thiru Er . A.Venkat achalam,M.E.,MIE .,
FIV., to include his name in the panel-Ordered.

Read:1) Application of Er.A.Venkatachalam, M.E., MIE.,
FIV., Dated: 21.01.2007.
2)Chennai Chief Engineer (General) P.W.D Lr No
AEE/TL/AE 1 / 60992/2010. Dated : 27.07.2010.


ORDER:

The Name of Er A.Venkatachalam M.E , MIE , FIV., Chartered Engineer,
Arrul, Associates, No1,Paramathi Road,Opp. to Municipal office, Namakkal
Taluk,Namakkal District is included in the panel of private practicing registered
Engineers of Namakkal district maintained in this office with the approval of the
Board of Engineers as laid down under the Rule 11 of the Tamilnadu Public
Buildings (licensing) Rules, 1966 for the issue of structural soundness certificate for
public buildings under Tamil Nadu Public Buildings (Licensing) Act, 1965.

2) He is registered under the category of Class IA (one A) (The value of
building work costing more than 30 lakhs).

(Sd)S.Madumathi
District Collector,
Namakkal.

/True Copy/



12.1.2011
For Collector
Namakkal

6/2


To
Er.A.Venkatachalam,M.E, MIV, FIV,
Arrul Associates,
No,1,Paramathy Road,
Opp.to Municipal Office,
Namakkal Taluk,
Namakkal District.


12/1/2011

Copy to the All Tahsildars.
Copy to 'C2' for stock File.


SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.




PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road.
Namakkal - 637 001.

FORM D

FORM OF LICENCE UNDER SUB - SECTION (1) OF SECTION 6 OF THE MADRAS PUBLIC BUILDINGS (LICENCING ACT,1965(MADRAS ACT 13 OF 1965)) REFERED TO IN RULE 6 OF THE MADRAS PUBLIC BUILDINGS (LICENCING) RULES, 1966

LICENCE

Licence No: 71/2024/A1

Fee Rs.1,000/- (Rupees One Thousand only)

Licence is hereby granted to **Spectrum Life School(CBSE)**, Trichy Road, Vagurampatty Village, 6/913, Nethaji Nagar 4th Cross NAMAKKAL TALUK AND NAMAKKAL DISTRICT, TAMILNADU STATE for the purpose and in respect of the Building specified in the statement below and subject to the condition and for the period mentioned hereunder:-

1. The period of validity of the licence shall be from (inclusive) 01.06.2025 to 31.05.2028.
2. The building should be used for the purpose for which this licence has been granted.
3. The number of persons to be accommodated in the building should not exceed the number noted in Col.3 of the statement accompanying the licence at a time.
4. The licence will not be valid for any addition or alternation made to this building before the date of expiry of the period of the licence. A Fresh licence will have to be obtained if any addition or alteration is made to the building.
5. Application for renewal of licence should be made not less than three months before the date of expiry of the current licence.
6. Any deviation from the rules and regulations of the Act under which this licence is issued will attract the levy of penalties, suspension, cancellation,etc of the licence.

Place: Namakkal
Date :18.12.2024.



M. Anirudh
SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.

[Signature]
SIGNATURE OF THE COMPETENT AUTHORITY
TAHSILDAR,
NAMAKKAL.

[Signature]
PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.

[Signature]
18/12/24

STATEMENT TO ACCOMPANY THE LICENCE

Location of the Building Door No., Street No. and Name of the Place	Purpose for which the Building is licensed to be used as a public building	Number of persons to be accomodated
(1)	(2)	(3)
SPECTRUM LIFE SCHOOL (CBSE), 6/913, NETHAJI NAGAR 4 TH CROSS, TRICHY ROAD, VAGURAMPATTY VILLAGE, NAMAKKAL TALUK AND DISTRICT, S.F. No. 5/2A(Part), 5/2B(Part), 21/2, 21/13, 21/16, 21/17.	EDUCATIONAL PURPOSE	Students - 1350 Nos Staff - 130 Nos <hr/> 1480 Nos <hr/>

Place : Namakkal

Date : 18.12.2024.



SIGNATURE OF THE COMPETENT AUTHORITY

TAHSILDAR,
NAMAKKAL.

[Signature]
18/12/24

H. Anirudha
SENIOR PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar, 4th Cross,
Trichy Road, Namakkal -637 001.

[Signature]
PRINCIPAL
SPECTRUM LIFE SCHOOL
6/913, Nethaji Nagar 4th Cross,
Trichy Road,
Namakkal - 637 001.